

Distt. Water testing Laboratory Public Health Engineering Division Chhatarpur (M.P.)

TEST REPORT

Nature of Sample :- Drinking Water Sample/ Others				Not sampled by Distt.Lab		Unique Identification No.	
Sender's name and address edify school district Chhatarpur (M.P.)	Sender's letter No		Sender's letter Date	2.3.2026			
	Distt.Lab Ref. No	406	Receipt date	2.3.2026			
	Date of analysis started	2.3.2026	Date analysis completed	3.3.2026			
	Quantity of Sample						

Sample details

No	Particulars of Samples
1	water sample of edify school district Chhatarpur(m.P.)
2	
3	

RESULTS

No	Characteristics unit and test methods	BIS-10500-2012		RESULTS		
		Desirable Limit	Permissibile Limit	1	2	3
1	2	3	4			
1	Temprature in digree C			19 °C		
2	Colour in Hazen scale	5	15	clear		
3	Odour	Agreeable	Agreeable	odourles		
4	Iron as Fe mg/l BIS 3025 part 53	1.0	1.0	0.2		
5	Nitrate as No3 mg/l PDA Method	45	45	31.2		
6	Fluoride as F mg/ltr BIS 3025 part 60	1.0	1.5	0.16		
7	Chloride as Cl in mg/l BIS 3025 part 32	250	1000	156		
8	Total Alkalinity as caco3 in mg/l BIS 3025	200.0	600	250		
9	Calcium as Ca in mg/l BIS 3025 part 40	75	200	125.1		
10	Magnesium as Mg in mg/l BIS 3025 part 46	30	100	15.6		
11	Sulphate as SO4 in mg/l BIS 3025 part 24	200	400	54.2		
12	pH BIS 3025 part 11	6.5 to 8.5	6.5 to 8.5	6.7		
13	Turbidity in NTU BIS 3025 part 10	1.0	5.0	2.4		
14	Total Hardness as CaCO3 in mg/l BIS3025 part	200	600	220.2		
15	Conductivity at 25oC as micromhos/cm2			650.8		
16	TDS mg/l By Meter	500	2000	351.2		
17	Manganese as mn in mg/l	0.1	0.3	NIL		
18	Feacal coliform (TTC) per 100 ml	NIL		NIL		
19	Total coliform per 100 ml	NIL for treated water and water in distribution system		NIL		


- 1 This report should not be produced partly or full without approval of signatory authority for legal purpose
- 2

It is recommended that acceptable limit is to be implemented .Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" in column 4 above which the source will have to be rejected

- 3 The results refer only to tested samples and parameters tested
- 4 This lab does not hold any responsibility for variation in results for for samples kept on hold for want of clarification.

Remarks:

Dotikera
CHEMIST
 Distt. water testing laboratory
 P.H.E.D. Chhatarpur (M.P.)
 P.H.E.O. Chhatarpur (M.P.)





Department of Finance , Government of Madhya Pradesh
Acknowledgement Receipt for Online Tax Payment
to M.P. State Government



TIN (Tax payment Identification Number) / Enrollment / Registration No.	
Depositor/Dealer Name	EDIFY SCHOOL
Address	EDIFY SCHOOL , CHHATARPUR , Chhatarpur, Madhya Pradesh - 471001
District selected for Payment	Chhatarpur
Unique Registration Number (URN)	MPTURN070320260002983
Department and Office Name	Public Health Engineering, EDIFY SCHOOL
Challan Payment Period	2025-2026
Purpose	water testing

Purpose Details

CRN	Assessment/ Concerning Period	Head of Account	Challan Identification Number (CIN)	Challan No.	Amount(Rs.)
MPT021507032026000003	2026-03-02 to 2026-03-03	0215-01-501-0164 (Services and Service Fees-Other Public Health Engineering Services)	SBIN0006159021507032026996894	051/9999999/0215/03/26/000045	1550.00

Total Amount(in figures)	1,550.00
Total Amount(in words)	One Thousand Five Hundred Fifty Rupees Only
Name and Code of the Bank	STATE BANK OF INDIA (2)
Bank Reference Number	CPAGKZNG11
Scroll No	99689
Scroll Date	07/03/2026
Date of Transaction / Time of Transaction (HH24:mm:ss)	07/03/2026 14:33:54
Transaction Status	Success

